



PRIEŠGAISRINĖS APSAUGOS IR GELBĖJIMO DEPARTAMENTO
 PRIE LIETUVOS RESPUBLIKOS VIDAUS REIKALŲ MINISTERIJOS
GAISRINIŲ TYRIMŲ CENTRAS

FIRE AND RESCUE DEPARTMENT UNDER THE MINISTRY OF INTERIOR
 OF THE REPUBLIC OF LITHUANIA
FIRE RESEARCH CENTRE

UAB "Elpa ir partneriai"
 Birutės Str. 2, LT- 5802 Klaipėda
 Tel. (8-46) 38 01 78, fax (8-46) 41 13 73

CONCLUSION No. EB-21/2004

CABLE CONFORMITY WITH THE LST EN 50265-2-1:1999

Issued on 22/03/2007

The Fire Research Centre of the Fire and Rescue Department under the Ministry of the Interior has tested

..... UAB "Elpa ir partneriai", Birutės Str. 2, LT- 5802 Klaipėda.....
 (manufacturer's name, address)

Land speaker cable "SA2,50T": two multi-core copper conductors, with outer transparent PVC insulation. External dimension of the cable is 3,8x7,0 mm.....
 (product name)

and has issued a test report (-s)...No. EB -21/2004.....
 (No. of test reports)

In accordance with the test results the cables of types SA0.35, SA0.35T, SA0.50, SA0.50T, SA0.75, SA0.75T, SA1.00, SA1.00T, SA1.20, SA1.20T, SA1.30, SA1.30T, SA1.50, SA1.50T, SA2.00, SA2.00T, SA2.50, SA2.50T, SA3.00, SA3.00T, SA4.00, SA4.00T, SA5.00T comply with the requirements of

.....LST EN 50265-2-1:1999 standard.....
 (reference number)

This document is valid jointly with the test report (-s).....EB -21/2004.....
 (test reports No.)

till.....22/03/2010.
 (expiry date)

Head of Fire Testing, Chemical and
 Radiation Research Division



Donatas Dipinskas

Chiefs Deputy of Fire Testing, Chemical and
 Radiation Research Division, Technical Manager

tyrimų
 centras
 Vitold Kostiukevič